

TYPICAL CEMENT CERTIFICATE

Masonry type

S

Physical tests

Time of set (minutes)

Gillmore

Initial..... 195

Final..... 370

Fineness

Retained on 45 µm

sieve (%)..... 5

Compressive strength (MPa [psi])

7 days..... 17.6 [2560]

28 days 21.6 [3140]

Autoclave expansion (%)..... 0.04

Water retention (%)..... 80

Air content (%)..... 17

**We hereby certify that the cement delivered complies with the
ASTM standard C 91 current requirements, Type S.**

For any information regarding this certificate, please contact our technical service at (418) 329-2100, ext. 3276.

**Michel Chabot, Eng.
Chemist Engineer**